



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Ex COMPONENT CERTIFICATE

Certificate No.: **IECEx EPS 12.0009U**

Page 1 of 4

Certificate history:

Status: **Current**

Issue No: 5

Issue 4 (2022-09-09)

Issue 3 (2021-11-16)

Issue 2 (2021-07-23)

Issue 1 (2012-10-17)

Issue 0 (2012-09-10)

Date of Issue: 2026-07-29

Applicant: **eltherm production GmbH**
Ernst-Heinkel-Straße 6-10
57299 Burbach
Germany

Ex Component: Heating cable Type ELP / PFA-....-....

This component is NOT intended to be used alone and requires additional consideration when incorporated into other equipment or systems for use in explosive atmospheres (refer to IEC 60079-0).

Type of Protection: **60079-30-1**

Marking: Ex 60079-30-1 IIC Gb

Ex 60079-30-1 IIIC Db

Approved for issue on behalf of the IECEx
Certification Body:

Ulrich Feike

Position:

Head of Certification

Signature:
(for printed version)

Date:
(for printed version)

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

Bureau Veritas Consumer Products Services Germany GmbH
Businesspark A96
86842 Türkheim
Germany





IECEX Certificate of Conformity

Certificate No.: **IECEX EPS 12.0009U**

Page 2 of 4

Date of issue: 2026-07-29

Issue No: 5

Manufacturer: **eltherm production GmbH**
Ernst-Heinkel-Straße 6-10
57299 Burbach
Germany

Manufacturing
locations: **eltherm production GmbH**
Ernst-Heinkel-Straße 6-10
57299 Burbach
Germany

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The component and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements
Edition: 7.0

IEC/IEEE 60079-30-1:2015 Explosive atmospheres - Part 30-1: Electrical resistance trace heating - General and testing requirements
Edition: 1.0

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the component listed has successfully met the examination and test requirements as recorded in:

Test Report:

DE/EPS/ExTR12.0018/04

Quality Assessment Report:

FR/INE/QAR12.0007/09



IECEx Certificate of Conformity

Certificate No.: **IECEx EPS 12.0009U**

Page 3 of 4

Date of issue: 2026-07-29

Issue No: 5

Ex Component(s) covered by this certificate is described below:

The heating cable type ELP / PFA-...-... is designed as a component for the inclusion in trace heating systems for hazardous areas.

Rated Voltage: 230 V AC / 277 V AC

type	dimensions approx. (mm)	power output (W/m) (at 230 V and 10°C)	cross-section	
			conductor	braid
ELP / PFA-...-...	8 x 5.5	15/30/45/60	1.5 mm ² or 4 mm ²	2 mm ²

For detailed specifications refer to the instruction manual QAA 129

SCHEDULE OF LIMITATIONS:

The connection method, the temperature class, (temperature limitation) and the requirements made on the qualification of the staff putting the regulations into practice, have to be defined in the certification of system in its final installation.

The maximum allowed sheath temperature is +250 °C.

The allowed continuous exposure temperature (trace heater de-energized) is from -60 °C to +250 °C.

The allowed maintain temperature (trace heater energized) ranges from:

- -60 °C to +200 °C for heaters with power output 15, 30, 45 W/m,
- -60 °C to +180 °C for heaters with power output 60 W/m.

The minimum bending radius is 25 mm.

The manufacturer's instructions must be followed.



IECEx Certificate of Conformity

Certificate No.: **IECEx EPS 12.0009U**

Page 4 of 4

Date of issue: 2026-07-29

Issue No: 5

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

Two new types of insulating material added: PFA Amboflon 15T and PFA HD962