



中国国家强制性产品认证证书



证书编号: 2023322312005692

认证委托人名称: 爱敦(上海)电伴热技术有限公司
认证委托人地址: 上海市浦东新区耀华路488号1501室
生产者名称: 爱敦公司
生产者地址: 德国布尔巴赫 Ernst-Heinkel-Str. 6-10, 57299
生产企业名称: 爱敦公司
企业地址: 德国布尔巴赫 Ernst-Heinkel-Str. 6-10, 57299
产品名称: 伴热电缆
系列、规格、型号: ELKM-AG-E
标 准: GB/T 3836.1-2021、GB/T 3836.3-2021、GB/T 3836.31-2021

认证模式: 型式试验+初始工厂检查+获证后监督

上述产品符合 CNCA-C23-01:2019 《强制性产品认证实施规则 防爆电气》的要求, 特发此证。
产品相关信息详见附件。

发证日期: 2023年12月05日

有效期至: 2028年12月04日

首次发证日期: 2023年12月05日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批 准:



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2023322312005692

APPLICANT: Eltherm (Shanghai) Company Limited
ADDRESS: Room1501, No.488 Yaohua Road Pudong New Area, Shanghai
China
MANUFACTURER: eltherm production GmbH
ADDRESS: Ernst-Heinkel-Str. 6-10, 57299 Burbach, Germany
FACTORY: eltherm production GmbH
ADDRESS: Ernst-Heinkel-Str. 6-10, 57299 Burbach, Germany
PRODUCT: Heating Cable
SERIES,SPECIFICATION,MODEL: ELKM-AG-E
STANDARDS: GB/T 3836.1-2021、GB/T 3836.3-2021、GB/T 3836.31-2021

Type of Certification: Type test + Initial inspection + Surveillance inspection

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).
Refer to the attachment for detailed information.

Valid from: December 5, 2023

Valid until: December 4, 2028

Date of original certification: December 5, 2023

The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiias.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

S 0008328



中国国家强制性产品认证证书



证书编号: 2023322312005692

附 件

产品名称: 伴热电缆

型号规格: ELKM-AG-E a

a 代表电阻值 Ω/m , 可为:

4. 4, 7. 2, 10, 11. 7, 15, 25, 31. 5, 50, 65, 80, 100, 157, 180, 200, 260, 280,
328, 360, 430, 480, 600, 800, 1000, 1470, 1750, 1900, 2900, 4000, 4700,
6000, 7000, 8000

防爆标志: Ex eb IIC Gb, Ex tb IIIC Db

电气参数: 额定电压: 750V AC

相关报告编号: 2023S17402-013013

使用条件:

1. 特殊 (限制) 使用条件
 - 1) 工作温度范围: $-60^{\circ}\text{C} \sim 260^{\circ}\text{C}$;
 - 2) 必须在最终安装系统的认证中规定连接方法、温度组别以及对实施规定的工作人员资格的要求。
 - 3) 产品仅能承受低冲击能量。使用时应避免机械冲击。
2. 最小弯曲半径: 2.5 倍电缆直径。

批 准:



上海仪器仪表自控系统检验测试所有限公司