中国国家强制性产品认证证书

证书编号：2021322313004191

认证委托人名称及地址
爱敦（上海）电伴热技术有限公司
上海市浦东新区耀华路 488 号 1501 室

生产者名称及地址
爱敦公司
德国布尔巴赫 Ernst-Heinkel-Str. 6-10, 57299

生产企业名称及地址
爱敦公司
德国布尔巴赫 Ernst-Heinkel-Str. 6-10, 57299

产品名称和系列、型号、规格
支架
Ex-It

产品标准和技术要求
GB/T 3836.1-2021、GB/T 3836.3-2021、GB/T 3836.31-2021

上述产品符合《强制性产品认证实施规则 防爆电气》
(CNCA-C23-01:2024)的要求，特发此证。
发证日期:2026 年 08 月 04 日　有效期至:2031 年 08 月 03 日

首次发证日期:2021 年 08 月 12 日
认证模式:型式试验+初始工厂检查+获证后监督

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。

批　准：

上海仪器仪表自控系统检验测试所有限公司

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2021322313004191

NAME AND ADDRESS OF THE APPLICANT
Eltherm (Shanghai) Company Limited
Room1501, No.488 Yaohua Road Pudong New Area, Shanghai China

NAME AND ADDRESS OF THE MANUFACTURER
eltherm production GmbH
Ernst-Heinkel-Str. 6-10, 57299 Burbach, Germany

NAME AND ADDRESS OF THE FACTORY
eltherm production GmbH
Ernst-Heinkel-Str. 6-10, 57299 Burbach, Germany

NAME, SERIES, MODEL AND SPECIFICATION
Mounting Post
Ex-It

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS
GB/T 3836.1-2021、GB/T 3836.3-2021、GB/T 3836.31-2021

This is to certify that the above-mentioned product(s)complies with the requirements of implementation rules for compulsory certification (CNCA-C23-01:2024).
Issue date:2026-08-04 Valid until:2031-08-03

Date of initial issue:2021-08-12
Type of Certification: Type test + Initial inspection + Surveillance inspection

The certificate details and validity can be verified by scanning the QR code below or logging into the issuing authority's official website. It can also be inquired on the CNCA website (www.cnca.gov.cn).

(In case of dispute, the Chinese text shall prevail.)

APPROVAL:

Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

http://www.sitias.com.cn 103 Cao Bao Road, Shanghai 200233,China Tel: +86 21 64518419

中国国家强制性产品认证证书

证书编号：2021322313004191
证书附页：第 1 页 共 1 页

产品名称：
支架

型号规格：
Ex-It

防爆标志：
Ex eb ⅡC Gb, Ex tb ⅢC Db

电气参数：
/

相关报告编号：
2023S17402-011624，2021S17402-005835

使用条件：
特殊（限制）使用条件：
1）支架为 Ex 元件，不能单独使用，与其它电气设备或系统一起使用时需附加认证。必须验证温度参数。
2）螺纹法兰、安装柱和密封件的工作温度不得超过相应材料的允许工作温度。
3）安装 Ex-It 型支架时，必须确保所用电缆安装牢固。必须为配套接线盒中的圆形电缆提供单独的夹具。
4）支架必须防止危险的静电电荷，例如，埋入至少 20 mm 厚的隔热层中。
5）只能使用经过测试和认证的、在许用电流密度下工作的加热导体。必须注意证书中包含的特殊条件和安全说明。
6）使用环境温度：-20℃～+60℃。

本页为证书附页，应与证书主页同时使用。

批 准：

上海仪器仪表自控系统检验测试所有限公司