



中国国家强制性产品认证证书



证书编号: 2021322310004187

认证委托人名称: 爱敦(上海)电伴热技术有限公司
认证委托人地址: 上海市浦东新区耀华路488号1501室
生产者名称: 爱敦公司
生产者地址: 德国布尔巴赫 Ernst-Heinkel-Str. 6-10, 57299
生产企业名称: 爱敦公司
企业地址: 德国布尔巴赫 Ernst-Heinkel-Str. 6-10, 57299
产品名称: 接头和终端装置
系列、规格、型号: Ex-It-L 和 Ex-It-S
标准: GB/T 3836.1-2021、GB/T 3836.3-2021、GB/T 3836.9-2021、
GB/T 3836.31-2021

认证模式: 型式试验+初始工厂检查+获证后监督

上述产品符合 CNCA-C23-01:2019 《强制性产品认证实施规则 防爆电气》的要求, 特发此证。
产品相关信息详见附件。

发证日期: 2023年04月23日

有效期至: 2026年08月11日

首次发证日期: 2021年08月12日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准:



上海仪器仪表自控系统检验测试所有限公司

<http://www.sitiias.com.cn>

中国·上海·漕宝路103号200233

电话: +86 21 64510844

S 0009730



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2021322310004187

APPLICANT: Eltherm (Shanghai) Company Limited
ADDRESS: Room1501, No.488 Yaohua Road Pudong New Area, Shanghai
China
MANUFACTURER: eltherm production GmbH
ADDRESS: Ernst-Heinkel-Str. 6-10, 57299 Burbach, Germany
FACTORY: eltherm production GmbH
ADDRESS: Ernst-Heinkel-Str. 6-10, 57299 Burbach, Germany
PRODUCT: Splice & Termination Device
SERIES,SPECIFICATION,MODEL: Ex-It-L and Ex-It-S
STANDARDS: GB/T 3836.1-2021、GB/T 3836.3-2021、GB/T 3836.9-2021、
GB/T 3836.31-2021

Type of Certification: Type test + Initial inspection + Surveillance inspection

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Refer to the attachment for detailed information.

Valid from:April 23, 2023

Valid until:August 11, 2026

Date of original certification:August 12, 2021

The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiias.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

s 0007716



中国国家强制性产品认证证书



证书编号: 2021322310004187

附 件

产品名称: 接头和终端装置

型号规格: Ex-It-L 和 Ex-It-S

防爆标志: Ex-It-L: Ex eb mb IIC T6 Gb, Ex tb IIIC T80°C Db;
Ex-It-S: Ex eb IIC T6 Gb, Ex tb IIIC T80°C Db

电气参数: 电压: 100~277 V AC, 功率: 4W(Ex-It-L)

相关报告编号: 2023S17402-011675, 2021S17402-005676

使用条件: 特殊(限制)使用条件
1) 使用环境温度: -20°C~+55°C
2) 仅能用湿布擦拭。
3) 产品不得在高起电工艺附近操作。
4) 只能使用 eltherm 公司的 EL-EOL 型照明装置。

批 准:



上海仪器仪表自控系统检验测试所有限公司